

Uwindow following EN ISO 10077-1

4 mm Planibel Low-e Top N+ pos.2
16 mm Argon 90%
4 mm Planibel Clear
16 mm Argon 90%
4 mm Planibel Low-e Top N+ pos.5

Glass Summary

$U_g = 0.6 \text{ W}/(\text{m}^2.\text{K})$
Spacer Type = Warm-edge
 $\Psi = 0.06 \text{ W}/\text{m}.\text{K}$

Frame Summary

1.48 m (height) x 1.23 m (width) = 1.82 m²
 $L_g = 7.5 \text{ m}$
Frame Type = PVC - PUR
 $U_f = 6.0 \text{ W}/(\text{m}^2.\text{K})$
Frame Fraction = 20 %

Window Thermal Transmission (U_w)

1.91 W/(m².K)



The calculations in this sheet are conform with EN ISO 10077-1.
This sheet may only be used or exploited by the customer who asked for this document
and exclusively for the purposes for which it was requested.

AGC Glass Europe

12-02-2014